



Newmark/Muscoy Conference Call Notes

6 July 2004 (1:30-3:00 P.M.)

Team Conference Call Members Present for Call:

- | | |
|--|---|
| <input checked="" type="checkbox"/> Dwayne Deutscher/URS | <input checked="" type="checkbox"/> Kim Hoang/EPA |
| <input checked="" type="checkbox"/> Dennis Bane/URS | <input type="checkbox"/> Jackie Lane/EPA |
| <input checked="" type="checkbox"/> Matt Dwyer/URS | |
| <input checked="" type="checkbox"/> Adam Harvey/URS | <input type="checkbox"/> Stacey Aldstadt/SBMWD |
| <input checked="" type="checkbox"/> Connie Biedel/URS | <input checked="" type="checkbox"/> Bill Bryden/SBMWD |
| | <input checked="" type="checkbox"/> Russell Smith/SBMWD |
| <input type="checkbox"/> Tom Perina/CH2M Hill | <input checked="" type="checkbox"/> Mark Eisen/SBMWD |
| <input type="checkbox"/> Bob Kemmerle/E2 | <input checked="" type="checkbox"/> Terry Tonn/SBMWD |
| | <input type="checkbox"/> Lana Kennerly /SBMWD |

Contract Issues

- Kim still waiting to hear from Linda and Barbara on the ceiling issue. If no response by end of next week (mid-July), Kim will modify WA's 69 and 116.
- Linda is working on WAF 116 to add \$76,000.
- Adam said when he and Matt were on site; he noticed the coating repair personnel were not using confined space safety precautions when entering a vessel. Adam contacted the URS Health and Safety Manager.

General

Construction:

- URS noticed the coating repair personnel were not using confined space safety precautions in the vessel. The URS Health and Safety Manager was contacted and the subcontractor was notified to follow its confined space safety program.
- Matt said they started the underground at Encanto Park Booster Station. The canal valve at 19th Street is complete.
- The bid for boring is due 14 July.
- Adam to start contact with Carbon Activated.

Next Conference Call:

Monday, 12 July; Call in #: 202-275-0170; Participant Code: 7860 (#).

The minutes of this meeting represent the writer's understanding of the events as discussed. Should an attendee's understanding differ, please contact Dwayne Deutscher at 916-679-2051, or dwayne_deutscher@urscorp.com. The minutes contained herein will stand if not corrected within ten (10) days of this writing.