



Newmark/Muscoy Conference Call Notes

5 December 2005 (1:30 P.M.)

Conference Call Members Present for Call:

- | | |
|--|---|
| <input checked="" type="checkbox"/> Dwayne Deutscher/URS | <input checked="" type="checkbox"/> Kim Hoang/EPA |
| <input checked="" type="checkbox"/> Dennis Bane/URS | <input type="checkbox"/> Jackie Lane/EPA |
| <input type="checkbox"/> Matt Dwyer/URS | <input type="checkbox"/> Stacey Aldstadt |
| <input checked="" type="checkbox"/> Adam Harvey/URS | <input type="checkbox"/> Robin Ohama/SBMWD |
| <input checked="" type="checkbox"/> Connie Biedel/URS | <input checked="" type="checkbox"/> Bill Bryden/SBMWD |
| <input checked="" type="checkbox"/> Kit Veldman/URS | <input type="checkbox"/> Dave Solomona/SBMWD |
| <input checked="" type="checkbox"/> Nick Reylek/URS | <input checked="" type="checkbox"/> Mark Eisen/Secor |
| <input type="checkbox"/> Tom Perina/CH2M Hill | <input type="checkbox"/> Terry Tonn/SBMWD |
| <input checked="" type="checkbox"/> Bob Kemmerle/E2 | <input checked="" type="checkbox"/> Mike Lowe/SBMWD |
| | <input checked="" type="checkbox"/> Lana Kennerly/SBMWD |

Contract Issues

- Linda/Evonne is aware of the changes that need to be made for the new WAF. Kim will put the new change of Period of Performance and new money in.
- Kim is still planning on getting the new work assignment sent out this month.

Construction (Adam Harvey)

- Continuing with the Attachment A items. The gauges need to be installed on the GAC vessels and the two pressure probes need to be reinstalled.
- The new cable was pulled in between the two RTU panels at 19th Street. ATSI is on site today putting the two processors in and isolators for lightening protection. The cable did not exhibit visual damage.
- Regarding the SixCENSE probe at Encanto Park, the manufacturer thinks they have found a solution to make the longer cable work, no details yet.

Well Construction

- Dennis will write executive summaries for the Monthly Report Results and send out as a PDF.
- Dennis just did the video log of the Darby Well, and water levels turned out to be a lot lower than the Capture Analysis indicates it should be.
- Lana will send comments on capture analysis by 14 December.
- Dennis will send comments via PDF to Kim, Lana, Mike Lowe, Bill, Mark, Bob, and Tom. Kim will also receive a hard copy.
- Lana/Stacy will keep Kim informed of activities from MUNI on lakes and streams.

General

- The next meeting is scheduled for 14 December, 10:00 AM – 5:00 PM. In particular, Kim would like to finalize the construction and go over any major points or issues, depending on the city. The monthly performance inspection is scheduled for 9:00 AM at the Treatment Plant.

Next Conference Call

Monday, 12 December 2005, 2:00 P.M., Call in #: 415-947-8520, Access Code 2332#

The minutes of this meeting represent the writer's understanding of the events as discussed. Should an attendee's understanding differ, please contact Dwayne Deutscher at 916-679-2051, or dwayne_deutscher@urscorp.com. The minutes contained herein will stand if not corrected within ten (10)

days of this writing.